

## WALWORTH COUNTY SANITATION SETBACKS

Setback	*Septic tank-treatment tank to any well, pond, stream, etc.	----- 25 feet
Minimums:	*Septic tank-treatment tank to a swimming pool	----- 5 feet
	*Septic tank-treatment tank to water service line	----- 10 feet
	*Septic tank-treatment tank to any building	----- 5 feet
	*Septic tank-treatment tank to a lot line	----- 2 feet
	*Seepage area to surface water (lake, pond, river, etc.)	----- 50 feet
	*Seepage area to any well	----- 50 feet
	*Seepage area to below grade foundation	----- 10 feet
	*Seepage area to habitable slab construction	----- 10 feet
	*Seepage area to a swimming pool	----- 15 feet
	*Seepage area to uninhabitable slab construction	----- 10 feet
	*Seepage area to building (dirt floor – uninhabited)	----- 10 feet
	*Seepage area to a water service line	----- 10 feet
	*Seepage area to lot line	----- 5 feet
	*Holding tank vent to fresh air inlet (window-door)	----- 10 feet
	*Holding tank to a building	----- 5 feet
	*Holding tank manhole must be within 25 feet to an all weather service road	
	*Well to building overhang	----- 2 feet

2/20/01

